



**Upper Merion Township
Fire and EMS Department
Division of Fire and Life Safety
Commercial Self-Inspection Program
Questions – Call (610) 205-8554**



Check each items on the first Monday of every month – Make corrections/repairs immediately

	AREA TO CONFIRM	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC
1	All designated EXITS are unlocked when open												
2	All designated EXITS are free from clutter												
3	All EXIT LIGHTS are operational												
4	All EMERGENCY LIGHTS are operational												
5	All FIRE EXTINGUISHERS are operational												
6	ELECTRICAL ROOM is free from combustibles												
7	All required FIRE PROTECTION SYSTEMS current												
8	Yearly Fire Extinguisher Inspection Due Date												
9	6 and 12 Year Extinguisher Inspection Due Dates												
10	Twice a Year Hood System Inspection Due Date												
11	Hood System Cleaning Due Dates												
12	Yearly Sprinkler System Inspection Due Date												
13	Yearly Standpipe System Inspection Due Date												

This Checklist should be used as a guide to be prepared for when Upper Merion Fire and EMS conducts Commercial Fire Prevention Inspections.